

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7270-0026:216 Page 1 of 1

CATEGORY: Heat Detector

LISTEE: Simplex, 100 Simplex Drive, Westminster, MA 01441-0001
Contact: Paul Mattern (978) 731-8542 *FAX (978) 731-8881

DESIGN: Model 4098-9733 electric combination rate compensated, fixed temperature, and rate of rise heat detector. Unit intended for use with models 4098-9789, -9791 or -9792 detector base (CSFM Listing No. 7300-0026:217). Refer to listee's printed data sheet for additional detailed product description and operational considerations.

RATING: 135°F and 155°F

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical/temperature ratings and UL label.

APPROVAL: Listed as heat detector for use with separately listed Simplex's 4100, 4010, 4020 and 4120 series fire alarm control units.

*Rev. 05-13-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 17, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**